## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

Page 1 of 1 LISTING No. 7300-1337:100

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Kastle Systems, 1501 Wilson Blvd., Arlington VA 22209

Contact: Rafael Molinari (703) 528-8800 \*FAX (703) 528-2103

DESIGN: Model QUAD fire/burglary alarm monitoring system. Type 2 central station, waterflow,

automatic, manual, and access control service. The unit provides data collection,

communication, logging, scheduling and display of functions for fire alarm, access control, burglar alarm, and general signaling service. Refer to listee's data sheet for detailed product

description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire/burglary alarm monitoring system when used in conjunction with a separately

listed compatible fire alarm control unit.

NOTE: Burglary and other non-fire related functions were not examined, however, these devices

may be performed simultaneously to fire function when installed per manufacturer's

instructions, applicable codes and ordinances.

\*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 22, 2004 Date Issued: Listing Expires June 30, 2005

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager